

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

## **DATE OF THIS VERSION:**

February 1, 2015

## **TITLE OF DOCUMENT:**

Steam and Condensate Heating Piping, 23 22 13

## **DATE OF VERSION BEING SUPERSEDED (old):**

March 1, 2010

## **DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Steam and Condensate Heating Piping, 23 22 13

## **SUMMARY OF CHANGES IN THIS VERSION:**

1. Added Section 01 33 23, Shop Drawings, Product Data, and Samples under Paragraph 1.2- Related Work.
2. Corrected the title of Section 23 07 11 to read HVAC and BOILER PLANT INSULATION.
3. Renumbered the paragraphs accordingly and revised the list under Paragraph 1.2 Related Work.
4. Corrected the section titles throughout this section to match the master list on the TIL.
5. Modified Paragraph 2.12.E to address the pressure requirement.
6. Modified Paragraph 2.12.G.2 to address the requirement of 4 bolt raised face flange.
7. Modified Paragraph 2.12.J.3 to address the requirement of stainless steel tubes.
8. Made general minor revisions.