

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION:

December 1, 2015

TITLE OF DOCUMENT:

Pad-Mounted, Liquid-Filled, Medium-Voltage Transformers, 26 12 19

DATE OF VERSION BEING SUPERSEDED (old):

December 1, 2012

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

Pad-Mounted, Liquid-Filled, Medium-Voltage Transformers, 26 12 19

SUMMARY OF CHANGES IN THIS VERSION:

1. Section 1.4B: Revised factory test requirement to be consistent with 26 05 11, General Electrical Requirements.
2. Section 1.6: Revised Applicable Standards to reflect latest editions. Revised to delete the rescinded NEMA TP 1. Revise to include Department of Energy (DOE) 10 CFR Part 431.
3. Section 2.9K: Revised to delete the rescinded NEMA TP 1 and its requirements. Replaced TP 1 with DOE's 10 CFR Part 431.