LIGHTING FIXTURE SCHEDULE

FIXT. NO.	DESCRIPTION	MANUFACTURER & CATALOG NO.	LAMPS QUANTITY AND WATTS FLUOR	INCAND	H.I.D.	ORDERING CODE	VOLTAGE	MOUNTING	NOTES
A1	8.25"W x 1.7"H pendant mounted linear fluorescent fixture with die punched perforactions, 96% uplight 4% downlight, white finish	Peerless BRM7 2 28T5 SPR XX XX 277 GEB10 XX DCT LP835 F1 XX" C210 DU	2 – 28			FP28T5	277	Pendant	refer to plans for fixture lengths and ceiling type and number of ballasts
B1	10" DIA. x 6.25" DEEP recessed vandal resistant lensed horizontal 1–lamp compact fluorescent downlight	Kirlin RV91003 –58	1 – 32			CF32TTT (GX24Q–3)	120	Ceiling (Recessed)	
D1	26.5" W x 10.25"H Compact Fluorescent fixture with 0.13" thick white accrylic diffusor with matte finish, UV stabalized and satin nickel metal finish	Visa Lighting CM1092 2TF32 SN	2–32			CF32TTT (GX24Q–3)	120 / 277	Ceiling (Surface)	
D2	7.34" DIA x 12.18"H pendant mounted compact fluorescent decorative fixture with spun aluminum housing, reflector and canopy	Focal Point FGR–C–1–18TT–E–120–C144	1–18			CF18TTT (GX24Q–3)	120 / 277	Ceiling (Pendant)	
D3	26"DIA x 2.7"H pendant mounted compact fluroescent fixture with luminous acrylic diffusor, 97% uplight and 3% downlight, painted silver finish	Focal Point FMEP–26–432TT–1C–S–M24–TS	4–32			Provided with Fixture	277	Ceiling (Pendant)	
E1	single sided white thermoplastic green LED exit sign	Lithonia LRP LED W 1 GC XX 120/277 ELN XX Optional Manufacturers: Dual–Lite, Sure–Lites, Lightolier				Provided with Fixture	120/277	Universal	Provide chevrons and mounting as indicated on drawings
E2	double sided white thermoplastic green LED exit sign	Lithonia LRP LED W 2 GMR XX 120/277 ELN XX Optional Manufacturers: Dual–Lite, Sure–Lites, Lightolier				Provided with Fixture	120/277	Universal	Provide chevrons and mounting as indicated on drawings
F2W	6" DIA. x 6.6" DEEP lensed compact fluorescent downlight with angled lamp and diffuse clear reflector finish	Lithonia Gotham DLWF 1/32TRT 6AR LD 277 WLP Optional Manufacturers: Halo Portfolio, Prescolite Architektur	1 – 32			CF32TTT (GX24Q–3)	277	Ceiling (Recessed)	
F2	6" DIA. x 10.9" DEEP open recessed compact fluorescent downlight with vertical lamp and diffuse clear reflector finish	Lithonia Gotham AFV 1/32TRT 6AR LD 277 Optional Manufacturers: Halo Portfolio, Prescolite Architektur	1 – 32			CF32TTT (GX24Q–3)	277	Ceiling (Recessed)	
L3	2' x 4' 3 – Lamp T5 Lensed Grid Troffer with Regressed Aluminum Door	Lithonia 2SP8 G 3 25T5 A12125 277 Optional Manufacturers: Metalux, Columbia, Day–Brite	2 – 28			FP28T5	277/120	Ceiling (Recessed)	
M1	4.6" SQ. LED steplight with concealed optic, short distribution optics, integral LED driver and brushed aluminum finish	Wininoa LED STEP01 SQU S 008 ND120V BAL				Lamp Included with Fixture	120	Wall (Recessed)	
Q2	4"SQ. surface mounted ADA fluorescent fixture with acrylic overlay, solid metal ends, damp location 2'–0" nominal length	Shaper Lighting 600 24 T5/2/14 277 DL Optional Manufacturers: Tech Lighting	2 – 14			FP14T5	120	Surface (wall)	refer to interior elevations for mounting height finish by architect
Q4	4"D x 6.9"H surface mounted ADA fluorescent fixture with acrylic overlay, perforated lamp shield, white 4'–0" nominal length	Prudential WAL 14 P 2T5 RXX TMW SC 277 WM RSE 10THD CL6497 Optional Manufacturers: Litecontrol	2 – 28			FP28T5	120 / 277	Surface (wall)	refer to interior elevations for mounting height finish by architect
R2	2' W x 4' H x 3.13" DEEP fluorescent 2–lamp T5 volumetric lighting fixture with regressed two–piece refractor system and linear faceted reflector	Lithonia 2RT5 28T5 MVOLT GEB95S LPM835P	2 – 28			FP28T5	120 / 277	Ceiling (Recessed)	refer to plans for ceiling condition
R5	2' W x 4' H x 3.13" DEEP fluorescent 2–lamp T5 volumetric lighting fixture with regressed two–piece refractor system and linear faceted reflector	Lithonia 2RT5 14T5 MVOLT GEB95S LPM835P	2 – 14			FP14T5	120 / 277	Ceiling (Recessed)	refer to plans for ceiling condition
T1	4' 1 – lamp T5 turret industrial fluorescent with symetrical reflector	Lithonia MS5 1 28T5 SMR MVOLT CEB10PS Optional Manufacturers: Metalux, Columbia, Day–Brite, Prudential	1 – 28			FP28T5	277	Ceiling or Wall (Surface or Chain 10'–0" A.F.F.)	
T2	4' 2 – lamp T5 turret industrial fluorescent with symetrical reflector	Lithonia MS5 2 28T5 SMR MVOLT CEB10PS Optional Manufacturers: Metalux, Columbia, Day–Brite, Prudential	2 – 28			FP28T5	277	Ceiling or Wall (Surface or Chain 10'–0" A.F.F.)	
U4	4' 1–lamp undercabinet T5 fixture with solid front grounded convenience outlet, rocker switch and lamp included	Lithonia UC5D 28 Optional Manufacturers: Fail–Safe, Kenall, ALCKO, Prudential	1 – 28			FP28T5	120	Undercabinet (Surface)	connect to nearest 120V normal receptacle circuit

LIGHTING FIXTURE SCHEDULE

FIXT.	DESCRIPTION	MANUFACTURER & CATALOG NO.	LAMPS QUANTITY AND WATTS			ORDERING	VOLTAGE	MOUNTING	NOTES
X1	21.25"DIA pole mounted metal halide decorative fixture with 36" curved arm mount and 12'–0" pole with die cast spun alum. components, wet location, type III distro.	Selux BPC L R3 1 H70 277 Optional Manufacturers: Bega, Invue			1 – 70	MP70/U/MED (ED17)	277		orient reflector as shown on drawings, fixture away from pole, mounted at 12'–0" overall height
X3	wall mounted ceramic metal halide recti–linear, IP66 rated fixture with integral ballast, integral photo cell, quartz restrike lamp, type III distribution with 10% uplight glow	Cooper ENT 39 MH 277 EB 3SG QAB PC (277) L Optional Manufacturers: Sistemalux, Bega			1 – 39	MC39T6 (G12)	277	Surface (Wall)	finish by architect
X4	wall mounted ceramic metal halide rectilinear, full–cutoff, IP66 rated fixture w/ integral ballast, integral photo cell, quartz restrike lamp and type III distribution	Cooper ENT 39 MH 277 EB 3S QAB PC (277) L Optional Manufacturers: Sistemalux, Bega			1 – 39	MC39T6 (G12)	277	Surface (Wall)	finish by architect
X5	wall mounted ceramic metal halide rectilinear, full–cutoff, IP66 rated fixture w/ integral ballast, integral photo cell, quartz restrike lamp and forward throw distribution	Cooper ENT 39 MH 277 EB 3SG QAB PC (277) L Optional Manufacturers: Sistemalux, Bega			1 – 39	MC39T6 (G12)	277	Surface (Wall)	finish by architect
Y1	ground mounted fountain luminaire with twin ports, 60 degree beam each, integral LED driver	Bega 8802LED Optional Manufacturers: We–ef				Provided with Fixture	120	Burial (Ground)	Arrow denotes optical orientation of reflectors 6 watts
Y2	submersible fountain light and remote LED driver	We–ef 607–1027 (fixture) + 697–8060 (remote LED driver) Optional Manufacturers: Bega				Provided with Fixture	120	Burial (Ground)	provide LED drivers as required and indicated on drawings 2 watts
Y3	uplight for tree and flag pole with 14 degree beam and concentric louver	Bega 8807MH (fixture) + 673 (concentric louver) Optional Manufacturers:			1 – 39	MC39T6 (G12)	120	Burial (Ground)	
Y4	under bench mounted LED light fixture 4'–0" nominal length IP67 rated for wet locations, includes LED drivers as required	Bega 8303LED (Fixture) + 576 (remote LED driver) Optional Manufacturers: We–ef, Winona				Provided with Fixture	120	Burial (Ground)	provide LED drivers as required and indicated on drawings 9.5 watts

NOTE: "D" suffix on fixture type denotes fixture that requires dimming.
Refer to drawings for voltage requirements where multiple voltages are indicated.

FULLY SPRINKLERED

Revisions: Date

CONSULTANTS:

ARCHITECT/ENGINEERS:

HDR Architecture, Inc
1101 King Street | Suite 400 | Alexandria, Virginia 22314-2944 | 703.518.8500
5426 Bay Center Drive | Suite 400 | Tampa, Florida 33609-3444 | 813.282.2493

Drawing Title: LIGHTING FIXTURE SCHEDULE

Approved: Project Director

Project Title: V.A. RICHMOND POLYTRAUMA TRANSITIONAL REHABILITATION CENTER

Location: HUNTER HOLMES McGUIRE

Date: 07/24/2008 | Checked: JSB | Drawn: JSB

Project Number: V101BP 0241 652-307

Building Number

Drawing Number: ES6-101

Dwg. of

Office of Facilities Management

Department of Veterans Affairs

VA FORM 08–6231, OCT 1978