MEDICAL GAS ALARM PANEL SCHEDULE

LOCATION	TYPE OF PANEL	GAGES	SERVICE INDICATOR LIGHTS
BOILER PLANT CONTROL OFFICE —OR— ENGINEERING CONTROL CENTER (ECC) —OR— OTHER LOCATION WITH ENGINEERING PERSONNEL SUPERVISION —AND— INTENSIVE CARE NURSING —OR— FIRE STATION —OR— PHONE SWITCHBOARD —OR— SECURITY OFFICE	MASTER (SYSTEM) ALARM PANEL	NO	LIQUID OXYGEN LEVEL LOW OXYGEN RESERVE SWITCHOVER OXYGEN RESERVE IN USE OXYGEN RESERVE LOW LIQUID LEVEL OXYGEN RESERVE PRESSURE LOW OXYGEN MAIN LINE PRESSURE LOW OXYGEN MAIN LINE PRESSURE HIGH NITROUS OXIDE CHANGE OVER TO SECONDARY NITROUS OXIDE RESERVE IN USE NITROUS OXIDE MAIN LINE PRESSURE LOW NITROUS OXIDE MAIN LINE PRESSURE HIGH NITROGEN CHANGE OVER TO SECONDARY NITROGEN RESERVE IN USE NITROGEN MAIN LINE PRESSURE LOW NITROGEN MAIN LINE PRESSURE HIGH MEDICAL AIR DEWPOINT HIGH MA COMPRESSOR MALFUNCTION MEDICAL AIR MAIN LINE PRESSURE LOW MEDICAL AIR MAIN LINE PRESSURE HIGH MA SYSTEM CARBON MONOXIDE HIGH DESICCANT DRYER MALFUNCTION DESICCANT DRYER POST FILTER DIRTY DESICCANT DRYER INLET FILTER DIRTY MAIN LINE FILTER BANK DIRTY MA REFRIGERATED DRYER POST FILTER DIRTY AFTER COOLER HIGH AIR TEMPERATURE MEDICAL VACUUM LINE VACUUM LOW MEDICAL VACUUM FILTER BACK PRESSURE TEST BUTTON
SURGERY CONTROL ROOM	AREA ALARM PANEL	YES	OXYGEN LINE PRESSURE ABNORMAL NITROUS OXIDE LINE PRESSURE ABNORMAL NITROGEN LINE PRESSURE ABNORMAL MEDICAL AIR LINE PRESSURE ABNORMAL MEDICAL VACUUM LINE VACUUM LOW TEST BUTTON
RECOVERY ROOMS CRITICAL CARE AREAS EMERGENCY AREAS PATIENT AREAS	AREA (ZONE) ALARM PANEL	YES	OXYGEN LINE PRESSURE ABNORMAL NITROUS OXIDE LINE PRESSURE ABNORMAL NITROGEN LINE PRESSURE ABNORMAL MEDICAL AIR LINE PRESSURE ABNORMAL MEDICAL VACUUM LINE VACUUM LOW TEST BUTTON

DESIGNER'S NOTES:

1. LOCATE MASTER ALARM PANELS IN CONFORMANCE WITH INDIVIDUAL MEDICAL CENTER OPERATING PRACTICES FOR CRITICAL ALARM LOCATIONS.
2. INDICATE ROOM NUMBERS WHERE PANELS ARE TO BE LOCATED.
3. ADD ADDITIONAL MIXED GAS ALARMS AS REQUIRED TO THE MASTER AND AREA ALARM PANELS.

Department of Veterans Affairs

DETAIL TITLE / MEDICAL GAS ALARM PANEL SCHEDULE

SCALE: NONE

DATE ISSUED: DECEMBER 1, 2015 CAD DETAIL NO.: SD226200-01.DWG