


SEQUENCE OF CONTROL

1. WHEN WASHER DOOR IS OPEN CONTROL DAMPER D1 OPENS AND CONTROL DAMPER D2 CLOSES.
2. WHEN WASHER DOOR IS CLOSED CONTROL DAMPER D1 CLOSES AND CONTROL DAMPER D2 OPENS.
3. MAINTAIN EXHAUST DUCT UNDER NEGATIVE PRESSURE THROUGHOUT ITS RUN.



EXHAUST DUCTWORK - CAGE WASHER

NTS

DESIGNER'S NOTES:

1. COORDINATE EXHAUST CFM WITH THE ARCHITECTURAL EQUIPMENT DRAWINGS.
2. COORDINATE DAMPER OPERATION WITH WASHER DOOR, THRU THE WASHER CONTROL PANEL.



Department of
Veterans Affairs

DETAIL TITLE / EXHAUST DUCTWORK - CAGE WASHER

SCALE :NONE

DATE ISSUED :MAY 2011

CADD DETAIL NO. : SD233100-22.DWG