

Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

DATE OF THIS VERSION (new)

September 1, 2020

TITLE OF DOCUMENT (new title if applicable):

General-Duty Valves for Plumbing Piping 22 05 23

DATE OF VERSION BEING SUPERSEDED (old):

September 1, 2015

DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):

General-Duty Valves for Plumbing Piping 22 05 23

SUMMARY OF CHANGES IN THIS VERSION:

1. Entire document was reformatted for automatic re-numbering during editing for a specific project.
2. Added "Where conflicts occur these specifications and the VHA standard will govern to paragraph 1.3 A.
3. Updated paragraph 1.3 APPLICABLE PUBLICATIONS by undating dates on standards, deleting obsolete standards.
4. Added paragraph 1.6 As Built Documentation for completeness.
5. Renamed paragraph 2.3 from Balancing Valves to Manual Balancing Valves.
6. Added paragraph 2.4 Thermostatic Balancing Valves to include self actuated thermostatically controlled balancing valves used to maintain return and supply hot water and cold water within acceptable limits for mitigation of legionella.
7. Added paragraph 3.2 L for the installation requirements for thermostatic balancing valves.
8. Throughout the documents standardized the verbiage from "larger" to "greater."
9. Added paragraph 3.5 Startup and Testing for completeness.