

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

## **DATE OF THIS VERSION:**

January 1, 2017

## **TITLE OF DOCUMENT:**

Medium –Voltage Cables, 26 05 13

## **DATE OF VERSION BEING SUPERSEDED (old):**

December 1, 2012

## **DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Medium –Voltage Cables, 26 05 13

## **SUMMARY OF CHANGES IN THIS VERSION:**

1. Section 1.3: Revised to provide clarity.
2. Section 1.4(A) & (B): Revised to provide clarity to factory testing requirements.
3. Section 1.5(A), (A)(2) & A(4): Revised to provide clarity to samples, and additional requirement for qualified workers who perform testing.
4. Section 1.6: Revised to show latest applicable publications.
5. Section 1.7(A): Revised to provide clarity.
6. Section 2.1(D)(2)(b): Revised to include cable type TR-XLPE.
7. Section 3.4(B): Revised to provide clarity.
8. Section 3.7: Revised to edit the entire section. Revised to delete On-line Partial Discharge test, and to include Tan Delta and VLF Withstand tests.