

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

**DATE OF THIS VERSION:**

February 1, 2016

**TITLE OF DOCUMENT:**

Firestopping, 07 84 00

**DATE OF VERSION BEING SUPERSEDED (old):**

October 1, 2015

**DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Firestopping, 07 84 00

**SUMMARY OF CHANGES IN THIS VERSION:**

1. The restriction on the use of products requiring heat activation to seal an opening by it's intumescence for use in firestop systems is removed from this spec. section