

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

**DATE OF THIS VERSION:**

January 1, 2015

**TITLE OF DOCUMENT:**

Dry-Pipe Sprinkler Systems, 21 13 16

**DATE OF VERSION BEING SUPERSEDED (old):**

September 1, 2011

**DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Water-Based Fire-Suppression Systems, 21 10 00

**SUMMARY OF CHANGES IN THIS VERSION:**

1. Created new Specification specifically for Dry-Pipe Sprinkler Systems.
2. Updated specification requirements to document compliance with the current edition of NFPA 13.
3. Updated submittal requirements.
4. Provided detailed product requirements.
5. Implemented requirements for supervisory nitrogen systems for Dry-Pipe Sprinkler Systems. An air supervisory system can be substituted for the supervisory nitrogen system where systems warrant it.
6. Black steel pipe is required for Dry-Pipe Sprinkler Systems.