

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

## **DATE OF THIS VERSION (new)**

December 1, 2016

## **TITLE OF DOCUMENT (new title if applicable):**

Domestic Water Heat Exchangers, 22 35 00

## **DATE OF VERSION BEING SUPERSEDED (old):**

September 1, 2015

## **DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Domestic Water Heat Exchangers, 22 35 00

## **SUMMARY OF CHANGES IN THIS VERSION:**

1. Updated 2.1.A SHELL AND TUBE, DOMESTIC WATER HEAT EXCHANGERS:
  - a. to include instantaneous as an option,
  - b. to include water in tubes as an option,
  - c. to include Heating Hot Water or steam in shell as an option
2. Updated 2.1.E SHELL AND TUBE, DOMESTIC WATER HEAT EXCHANGERS:
  - a. to include copper alloy as an option,
  - b. to include straight tube configuration as an option.
3. Updated 2.1.F.1 SHELL AND TUBE, DOMESTIC WATER HEAT EXCHANGERS:
  - a. Added "if required" for steam control valve,
  - b. to include water control valve as an option,
  - c. to include mechanical control as an option.
4. Updated 2.1.F.3 SHELL AND TUBE, DOMESTIC WATER HEAT EXCHANGERS:
  - a. Added "if required" for Heating Hot Water control valve,
  - b. to include water control valve as an option.
5. Updated 2.1.I SHELL AND TUBE, DOMESTIC WATER HEAT EXCHANGERS:
  - a. to include shell of the exchanger as an option.
6. Updated 2.2.H CIRCULATING DOMESTIC WATER HEAT EXCHANGERS:

- a. removed helix wound from beginning of sentence and changed to an option,
- b. to include copper alloy as an option,
- c. to include straight tube configuration as an option.