

# Summary of Modifications/Changes in this Update

This Summary of Changes is for information only.  
It is not a part of the referenced document, and should not be used for project documentation.

U.S. Department of Veterans Affairs ♦ Office of Construction & Facilities Management

**DATE OF THIS VERSION:**

December 1, 2015

**TITLE OF DOCUMENT:**

Overcurrent Protective Device Coordination Study, 26 05 73

**DATE OF VERSION BEING SUPERSEDED (old):**

December 1, 2012

**DESCRIPTION OF DOCUMENT (previous title, number, other identifying data):**

Overcurrent Protective Device Coordination Study, 26 05 73

**SUMMARY OF CHANGES IN THIS VERSION:**

1. Section 1.3B: Revised to require that the study is to be performed by the equipment manufacturer's licensed electrical engineer.
2. Section 1.5: Revised to show latest edition of applicable publications. Revised to include IEEE 1584A and 1584B. Revised to include IEEE 241, NFPA 70, 70E and 99.
3. Section 1.6F: Revide to include this new section to require arc flash calculations and analysis.